PUBLIC HEALTH ENGINEERING DEPARTMENTLABORATORY, SAWAIMADHOPUR (RAJASTHAN)

CHEMICAL REPORT NRDWP 2020-21.

Date :- 17.5.21

No. LAB/Tech./2020-21/ 226

To, AEN PHED
City Sub Div. SKM

Name of Sender :-
Name of Sample Taker :- Bharat Meena
Your Letter No:- 101

Date of Collection:- 26-4-21
Date of Received:- 26-4-21

Sample No.	Date Of Exam	Name of Block	Name GP	Village	Sources	Particular of Source	pH	No3	F	Cl	Alk	T.H.	TDS
Max. Permissible Limits as per IS – 10500-03							6.5-8.5	<45 mg/l	<1.5 mg/l	<1000 mg/l	<600 mg/l	<600 mg/l	<2000 mg/l
51	26-4-21	SKIM	-	SKIM	T.kl.	Central School - Thingla	7.8	15	0.2	~~190~~ 160	290	290	730

Vishram singh Meena
Junior Chemist
PHED Lab. Sawaimadhopur
Date :-.....

No. LAB/Tech./2020-21/.....
Copy to.-
1. XEN PHED DIV SAWAIMADHPOPUR/GANGAPUR

Vishram singh Meena
Junior Chemist